

May 14th TRC Notes

- Planning: N/A
- Addressing: Using the same address that's been used. 1790 Altamahaw Union Ridge Road
- Fire: Parking Lot needs to be proof rolled 50,000 lbs.
- Planning Board: N/A
- NC Dot: Include the Dimensions of the Driveway
- Inspections: Submit construction drawings. Building Front/Side setbacks. Need construction plans submitted in PDF form to plan-review.
- Environmental health: Not to run driveway/parking lot in the septic area.